

Government Of West Bengal Office Of The Director General West Bengal Fire & Emergency Services 13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/69011

Date: 14-12-2023

From:

Divisional Fire Officer rire Prevention Wing. West Bengal Fire & Emergency Services

To: MR. TAPAS RANJAN BERA 1 NO, MOIRA STREET, KOLKATA-700017

Sub: Renewal of Fire Safety Certificate for the G+IV storied building under group Educational Building in Name & Style of "Birla Boys High School" at premises no.- 1no. Moira Street, Kolkata-700017.

This is in reference to your application no. 0125191238701071 dated 17-11-2023 regarding the Renewal of Fire Safety Certificate for the G+IV storied building under group Educational Building in Name & Style of "Birla Boys High School" at premises no. - 1no. Moira Street, Kolkata- 700017.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1. Driveway must be kept free of any type of obstruction for EASY movement of Fire Appliances. Parking shall not be
- 2. Provide open able type window at all floor area as per I.S. and NBC for smoke extraction at the time of exigency
- 3. The interior finish decoration of building shall be made with low flame spread material conforming I.S. specification.
- 4. To eliminate risk of Fire Hazard, good housekeeping both for inside and outside for the building shall be strictly maintained.
- 5. Electrical wiring of the whole building shall have to be carefully checked for any wear & tear in them, particularly lines above falls ceiling and duct.
- 6. The notice of Fire Fighting, Floor nos. and evacuation from the building shall be displayed at all vulnerable places of the building.

The authenticity of this document can be verified by accessing the URL: ediatrict.wb.gov in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125101238701071

Page: 1

- 7. A Fire control room including a C,C.T.V. system to be maintained which will observe all the floor of the building.
- 8. The employees and the security staffs shall be conversant with installed Fire Fighting Equipment of the building and to operate in the event of Fire & Testing.
- 9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
- 10. Switch Gear room shall be protected with automatic CO2 or D.C.P., Water spray projector system Fire extinguisher conforming I.S. specification.
- 11. First Aid Fire Fighting system shall be maintained as per I.S. specification.
- 12. Electrical ducts always to be kept in sealed condition with fire resisting materials.
- 13. The management of the organization/building as the case may be shall maintain the fire prevention & safety measures in good repair and in efficient condition at all times which are installed in the said building for use at the time of fire or other emergencies.
- 14. Periodical flashing of water from the hydrants & sprinkler pipe line shall be made to maintain the efficient working performance of above mentioned system.
- 45. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
- 16. Fire pump always to be kept in auto mode condition.
- 18. Mechanical ventilation shall be in working condition all the time.
- 19. This Renewal of Fire Safety Certificate is valid for three years from date of issue & have to be renewed within the validity limit from the date of issue of this letter from the Director General, West Bengal Fire & Emergency Services.

Signature val

Divisional Fire Officer West Bengal Fire & Emergency Services